





EMERGENCY	
automatic L1 fire alarm with new panel interfaced with main building to suit BS9999 & LFB requirement fire alarm design to BS 5839 with music & hvac to cut out upon activation. indicative locations shown to be designed, fitted & certified by specialist. all fire exit signage to comply with BS5499 part 1.	
<b>EES</b>	LIT EMERGENCY EXIT SIGN - 04no. ceiling or bulkhead mounted blade sign led. 3 hour battery colour: black. green running man arrows in exit direction.
<b>FES</b>	FIRE EXIT SIGN - 01no. wall or bulkhead mounted sticker green running man with arrow in exit direction.
<b>PUSH</b>	PUSH PAD TO OPEN NOTICE - 01no.
<b>KS</b>	FIRE DOOR KEEP SHUT NOTICE - 00no.
<b>KL</b>	FIRE DOOR KEEP LOCKED NOTICE - 04no.
<b>VPF</b>	VISION PANEL FITTED TO DOOR - 03no.
<b>H</b>	HEAT DETECTOR WITH SOUNDER & BEACON - 01no.
<b>SMO</b>	SMOKE DETECTOR - 06no.
<b>SMO2</b>	SMOKE DETECTOR WITH SOUNDER & BEACON - 02no.
<b>SMO2</b>	SMOKE DETECTOR WITH SOUNDER - 02no.
<b>FACP</b>	FIRE ALARM CONTROL PANEL - 00no.
<b>I/F</b>	FIRE ALARM INTERFACE - 00no.
<b>FO</b>	FOAM FIRE EXTINGUISHER - 02no.
<b>C02</b>	CO2 FIRE EXTINGUISHER - 02no.
<b>CP</b>	CALL POINT BREAK GLASS - 02no.
SHOPLIGHT EMERGENCY LIGHTS	
all emergency lighting to comply with BS5266 part 1 and table 9. indicative locations shown to be designed by shoplight & fitted & certified by electrician.	
<b>REM</b>	RECESSED EMERGENCY LIGHT - 02no. recessed emergency mini spot complete with 3 hour integral battery & driver. white.
<b>SEM</b>	SURFACE EMERGENCY LIGHT - 03no. surface emergency mini spot complete with 3 hour integral battery & driver. black.
<b>TEM</b>	TRACK MOUNTED EMERGENCY LIGHT - 06no. track mounted emergency spot light complete with 3 hour integral battery & driver. black to match track.

LICENSING LEGEND	
	LICENSING ACTIVITIES indicated areas only to be used for licensing activities

CLIENT		
TITLE	basement licensing plan	
DRAWING No.	TD23/RK06/10.2	
LOCATION	SPITALFIELDS	SCALE
4-10 Artillery Lane London E1 7LS	REVISION	DATE
		16.02.24
		1:25@A1
		1:50@A3

SCALE BAR	0 0.5 1M
REVISIONS	

All dimensions to be confirmed on site by Contractor. Structural works to be confirmed by Structural Engineer. All elements to comply with statutory requirements.

Copyright Tanner Design Limited, Marcar House 13 Parkshot Richmond Surrey TW9 2RG tel. 07974 324216 email. studio@tannerdesign.co.uk www.tannerdesign.co.uk

**TANNER**