Martin Marti Martin Martin Martin Martin Martin Martin Martin Martin Mart

PLEASE NOTE -

FIRE PANEL LOCATION INDICATED REAR OF UNIT T.B.C

FLASHING BEACON LOCATED TO REAR ENTRIES AND LINKED TO TENANT FIP

LANDLORD AND TENANT INTERFACES TO BE APPLIED TO SOUND SYSTEMS FOR ISOLATION


AUTOMATIC DETECTION SYSTEM L1+M AND SOUNDERS THROUGHOUT CONTRACTOR TO ENSURE APPLIED TO ALL VOIDS AND INTERNALS OF BULK HEADS


REDLINE OUTLINE INDICATES AREAS OF LICENSED ACTIVITIES

Emergency Lighting: emergency lighting is in compliance with BS5266 Part 1, Category M2 and will provide maintained emergency lighting for 3 hours duration.

Fire alarm to be installed as an L1 system by proposed contractor

Fire Alarm: the proposed fire alarm will be in accordance with BS5839 Part 1 and BS9899 and installations will be LPC approved and undertaken by an LPC approved installer to LPS 1014.





## **GROUND FLOOR PLAN VIEW SCALE 1:100**

clie	nt				_
	URBAN PL	BS AND	BARS		
tit	awing le .ICENSING	LAYOUT			
tit	le ICENSING	LAYOUT			
scal	le ICENSING		irawn by		
scal	le LICENSING	3			
scal	le @ A1 e @ A1 e DEC 202 g. no. UB/MIL/9	3	irawn by		
scal	le @ A1 e @ A1 e DEC 202 g. no. UB/MIL/9 ONE (0 WWW.C	3 ( 42/02 17766883 DULECTIV	irawn by	CO.UP	